

**BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT**

NAME OF PWS: El Paso Water PWS I.D. #: 0710002

OWNER NAME: \_\_\_\_\_

BUSINESS NAME: EL Paso Paper Box

MAILING ADDRESS: 24 Zane Grey St City: EL Paso State: Tx Zip: 79906

CUSTOMER REPRESENTATIVE: \_\_\_\_\_ Phone: \_\_\_\_\_ E-mail: \_\_\_\_\_

PREMISE ADDRESS: 24 Zane Grey St City: EL Paso State: Tx Zip: 79906

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

**TYPE OF ASSEMBLY**

- Reduced Pressure Principle
- Double Check Valve
- Pressure Vacuum Breaker

Meter Serial Number: 17147081

- Reduced Pressure Principle-Detector
- Double Check-Detector
- Spill-Resistant Pressure Vacuum Breaker

Manufacturer: Febco

Size: 1 1/2"

Model Number: 765

Located At: North Side of Hwy

Serial Number: H031239

- Domestic
- Fire Protection
- Lawn Irrigation

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? yes

	Reduced pressure Principle Assembly			Pressure Vacuum Breaker	
	Double Check Valve Assembly		Relief Valve	Air Inlet	Check Valve
	1st Check	2nd Check			
Initial Test	Held at _____ psid Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Held at _____ psid Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Opened at _____ psid Did not open <input type="checkbox"/>	Opened at _____ psid Did not open <input type="checkbox"/>	Held at <u>1.3</u> psid Leaked <input type="checkbox"/>
Repairs and Materials Used					
Test After Repair	Held at _____ psid Closed Tight <input type="checkbox"/>	Held at _____ psid Closed Tight <input type="checkbox"/>	Opened at _____ psid	Opened at _____ psid	Held at _____ psid

Test Date: 2/10/20 Test Type:  Initial  Annual  Repair  Relocation

Test Gauge Used: Make/Model: Pro Master S/N: 0854 Calibration Date: 1-3-25 OR 11/6/25

Removed Assembly: Manufacturer: \_\_\_\_\_ Model: \_\_\_\_\_ Size: \_\_\_\_\_ S/N: \_\_\_\_\_

Remarks: \_\_\_\_\_

The above is certified to be true at the time of testing.

Firm Name: TDE Backflow Services Certified Tester Name: Octavio Ramirez (Tavo)

Firm Address: 10219 Conquistador Cert. Tester #: BP0001229 Lic. Exp. Date: 3-22-26

Firm Phone: 915-873-0873 EPWU Technician #: 539

\* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS  
\*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS

**BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT**

NAME OF PWS: El Paso Water PWS I.D. #: 0710002

OWNER NAME: \_\_\_\_\_

BUSINESS NAME: EL Paso Paper Box

MAILING ADDRESS: 24 Zane Grey St City: El Paso State: Tx Zip: 79906

CUSTOMER REPRESENTATIVE: \_\_\_\_\_ Phone: \_\_\_\_\_ E-mail: \_\_\_\_\_

PREMISE ADDRESS: 24 Zane Grey St City: El Paso State: Tx Zip: 79906

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

**TYPE OF ASSEMBLY**

- Reduced Pressure Principle
- Double Check Valve
- Pressure Vacuum Breaker

- Meter Serial Number: 17147081
- Reduced Pressure Principle-Detector
  - Double Check-Detector
  - Spill-Resistant Pressure Vacuum Breaker

Manufacturer: Wilkins  
 Model Number: 375  
 Serial Number: M0357

Size: 3" P.V.# 35364  
 Located At: North side of Bldg  
 Domestic     Fire Protection     Lawn Irrigation

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? yes

	Reduced pressure Principle Assembly			Pressure Vacuum Breaker	
	Double Check Valve Assembly		Relief Valve	Air Inlet	Check Valve
	1st Check	2nd Check			
Initial Test	Held at <u>7.6</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>1.6</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Opened at <u>3.2</u> psid Did not open <input type="checkbox"/>	Opened at _____ psid Did not open <input type="checkbox"/>	Held at _____ psid Leaked <input type="checkbox"/>
Repairs and Materials Used					
Test After Repair	Held at _____ psid Closed Tight <input type="checkbox"/>	Held at _____ psid Closed Tight <input type="checkbox"/>	Opened at _____ psid	Opened at _____ psid	Held at _____ psid

Test Date: 2/6/26 Test Type:  Initial  Annual  Repair  Relocation  
 Test Gauge Used: Make/Model: Pro Master S/N: 0854 Calibration Date: 1-3-25 OR 11/6/25  
 Removed Assembly: Manufacturer: \_\_\_\_\_ Model: \_\_\_\_\_ Size: \_\_\_\_\_ S/N: \_\_\_\_\_

Remarks: \_\_\_\_\_  
 The above is certified to be true at the time of testing.

Firm Name: TDE Backflow Services Certified Tester Name: Octavio Ramirez (Tavo)  
 Firm Address: 10219 Conquistador Cert. Tester #: BP0001229 Lic. Exp. Date: 3-22-26  
 Firm Phone: 915-873-0873 EPWU Technician #: \_\_\_\_\_ 539

\* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS  
 \*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS

**BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT**

NAME OF PWS: El Paso Water PWS I.D. #: 0710002

OWNER NAME: \_\_\_\_\_

BUSINESS NAME: El Paso Paper Box

MAILING ADDRESS: 24 Zane Grey St City: El Paso State: Tx Zip: 79906

CUSTOMER REPRESENTATIVE: \_\_\_\_\_ Phone: \_\_\_\_\_ E-mail: \_\_\_\_\_

PREMISE ADDRESS: 24 Zane Grey St City: El Paso State: Tx Zip: 79906

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

**TYPE OF ASSEMBLY**

- Reduced Pressure Principle
- Double Check Valve
- Pressure Vacuum Breaker

Meter Serial Number: 20969790

- Reduced Pressure Principle-Detector
- Double Check-Detector
- Spill-Resistant Pressure Vacuum Breaker

Manufacturer: Wilkins Size: 8"

Model Number: 375 Located At: west side of Bldg

Serial Number: M13250  Domestic  Fire Protection  Lawn Irrigation

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? yes

	Reduced pressure Principle Assembly			Pressure Vacuum Breaker	
	Double Check Valve Assembly		Relief Valve	Air Inlet	Check Valve
	1st Check	2nd Check			
Initial Test	Held at <u>7.4</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>1.6</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Opened at <u>3.2</u> psid Did not open <input type="checkbox"/>	Opened at <u>3.2</u> psid Did not open <input type="checkbox"/>	Held at _____ psid Leaked <input type="checkbox"/>
Repairs and Materials Used					
Test After Repair	Held at _____ psid Closed Tight <input type="checkbox"/>	Held at _____ psid Closed Tight <input type="checkbox"/>	Opened at _____ psid	Opened at _____ psid	Held at _____ psid

Test Date: 2/6/26 Test Type:  Initial  Annual  Repair  Relocation

Test Gauge Used: Make/Model: Pro Master S/N: 0854 Calibration Date: 1-3-25 <sup>OR</sup> 11/6/25

Removed Assembly: Manufacturer: \_\_\_\_\_ Model: \_\_\_\_\_ Size: \_\_\_\_\_ S/N: \_\_\_\_\_

Remarks: \_\_\_\_\_

The above is certified to be true at the time of testing.

Firm Name: NEW-TEX Fire Protection Sys LLC Certified Tester Name: Octavio Ramirez (Tavo)

Firm Address: 5696 Burning Tree Cert. Tester #: BP0001229 Lic. Exp. Date: 3-22-26

Firm Phone: 915-873-0873 EPWU Technician #: 834

\* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS  
\*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS

*OR*

**BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT**

NAME OF PWS: El Paso Water PWS I.D. #: 0710002

OWNER NAME: \_\_\_\_\_

BUSINESS NAME: El Paso Paper Box

MAILING ADDRESS: 24 Zane Grey St City: EL Paso State: Tx Zip: 79906

CUSTOMER REPRESENTATIVE: \_\_\_\_\_ Phone: \_\_\_\_\_ E-mail: \_\_\_\_\_

PREMISE ADDRESS: 24 Zane Grey St City: EL Paso State: Tx Zip: 79906

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

**TYPE OF ASSEMBLY**

- Reduced Pressure Principle
- Double Check Valve
- Pressure Vacuum Breaker

Meter Serial Number: 20969790

- Reduced Pressure Principle-Detector
- Double Check-Detector
- Spill-Resistant Pressure Vacuum Breaker

Manufacturer: Wilkins

Size: 3/4

Model Number: 975XL

Located At: west side of Blkg

Serial Number: 4889523

- Domestic
- Fire Protection
- Lawn Irrigation

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? yes

	Reduced pressure Principle Assembly			Pressure Vacuum Breaker	
	Double Check Valve Assembly		Relief Valve	Air Inlet	Check Valve
	1st Check	2nd Check			
Initial Test	Held at <u>8.1</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>1.7</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Opened at <u>3.6</u> psid Did not open <input type="checkbox"/>	Opened at _____ psid Did not open <input type="checkbox"/>	Held at _____ psid Leaked <input type="checkbox"/>
Repairs and Materials Used					
Test After Repair	Held at _____ psid Closed Tight <input type="checkbox"/>	Held at _____ psid Closed Tight <input type="checkbox"/>	Opened at _____ psid	Opened at _____ psid	Held at _____ psid

Test Date: 2/6/26 Test Type:  Initial  Annual  Repair  Relocation

Test Gauge Used: Make/Model: Pro Master S/N: 0854 Calibration Date: 12/25 OR 11/6/25

Removed Assembly: Manufacturer: \_\_\_\_\_ Model: \_\_\_\_\_ Size: \_\_\_\_\_ S/N: \_\_\_\_\_

Remarks: \_\_\_\_\_

The above is certified to be true at the time of testing.

Firm Name: NEW-TEX Fire Protection Sys LLC Certified Tester Name: Octavio Ramirez (Tavo)

Firm Address: 5696 Burning Tree Cert. Tester #: BP0001229 Lic. Exp. Date: 3-22-26

Firm Phone: 915-873-0873 EPWU Technician #: 834

\* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS  
\*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS

El Paso Water - 210 N. Lee Street - El Paso, TX 79901 - Phone (915) 594-5440 - Fax (915) 594-5789

**BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT**

NAME OF PWS: El Paso Water PWS I.D. #: 0710002

OWNER NAME: \_\_\_\_\_

BUSINESS NAME: EL Paso Paper Box

MAILING ADDRESS: 24 Zane Grey St City: EL Paso State: Tx Zip: 79906

CUSTOMER REPRESENTATIVE: \_\_\_\_\_ Phone: \_\_\_\_\_ E-mail: \_\_\_\_\_

PREMISE ADDRESS: 24 Zane Grey St City: EL Paso State: Tx Zip: 79906

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

**TYPE OF ASSEMBLY**

- Reduced Pressure Principle
- Double Check Valve
- Pressure Vacuum Breaker

- Meter Serial Number: 17147081
- Reduced Pressure Principle-Detector
  - Double Check-Detector
  - Spill-Resistant Pressure Vacuum Breaker

Manufacturer: Wilkins  
 Model Number: 975 XL  
 Serial Number: 3416782

Size: 1/2  
 Located At: north side of Bldg  
 Domestic     Fire Protection     Lawn Irrigation

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? yes

	Reduced pressure Principle Assembly			Pressure Vacuum Breaker	
	Double Check Valve Assembly		Relief Valve	Air Inlet	Check Valve
	1st Check	2nd Check			
Initial Test	Held at <u>7.1</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>1.3</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Opened at <u>2.9</u> psid Did not open <input type="checkbox"/>	Opened at <u>2.9</u> psid Did not open <input type="checkbox"/>	Held at _____ psid Leaked <input type="checkbox"/>
Repairs and Materials Used					
Test After Repair	Held at _____ psid Closed Tight <input type="checkbox"/>	Held at _____ psid Closed Tight <input type="checkbox"/>	Opened at _____ psid	Opened at _____ psid	Held at _____ psid

Test Date: 2/6/26 Test Type:  Initial  Annual  Repair  Relocation

Test Gauge Used: Make/Model: Pro Master S/N: 0854 Calibration Date: 11/25/25 OR 11/6/25

Removed Assembly: Manufacturer: \_\_\_\_\_ Model: \_\_\_\_\_ Size: \_\_\_\_\_ S/N: \_\_\_\_\_

Remarks: \_\_\_\_\_  
 The above is certified to be true at the time of testing.

Firm Name: TDE Backflow Services Certified Tester Name: Octavio Ramirez (Tavo)

Firm Address: 10219 Conquistador Cert. Tester #: BP0001229 Lic. Exp. Date: 3-22-26

Firm Phone: 915-873-0873 EPWU Technician #: \_\_\_\_\_ 539

\* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS  
 \*\* USE ONLY MANUFACTURER'S REPLACEMENT PARTS