

BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

NAME OF PWS: El Paso Water PWS I.D. #: 0710002

OWNER NAME: _____

BUSINESS NAME: El Paso Paper Box

MAILING ADDRESS: 24 Zane Grey St City: El Paso State: Tx Zip: 79906

CUSTOMER REPRESENTATIVE: _____ Phone: _____ E-mail: _____

PREMISE ADDRESS: 24 Zane Grey St City: El Paso State: Tx Zip: 79906

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

TYPE OF ASSEMBLY

- ☐ Reduced Pressure Principle
☐ Double Check Valve
☐ Pressure Vacuum Breaker

Meter Serial Number: 20969790

- ☒ Reduced Pressure Principle-Detector
☐ Double Check-Detector
☐ Spill-Resistant Pressure Vacuum Breaker

Manufacturer: Wilkins Size: 8"

Model Number: 375 Located At: West side of Bldg

Serial Number: _____ ☐ Domestic ☒ Fire Protection ☐ Lawn Irrigation

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? yes

	Reduced pressure Principle Assembly			Pressure Vacuum Breaker	
	Double Check Valve Assembly		Relief Valve	Air Inlet	Check Valve
	1st Check	2nd Check			
Initial Test	Held at <u>7.8</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>1.8</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Opened at <u>3.4</u> psid Did not open <input type="checkbox"/>	Opened at _____ psid Did not open <input type="checkbox"/>	Held at _____ psid Leaked <input type="checkbox"/>
Repairs and Materials Used					
Test After Repair	Held at _____ psid Closed Tight <input type="checkbox"/>	Held at _____ psid Closed Tight <input type="checkbox"/>	Opened at _____ psid	Opened at _____ psid	Held at _____ psid

Test Date: 4/11/24 Test Type: ☐ Initial ☒ Annual ☐ Repair ☐ Relocation

Test Gauge Used: Make/Model: Pro Master S/N: 0854 Calibration Date: 1-10-23

Removed Assembly: Manufacturer: _____ Model: _____ Size: _____ S/N: _____

Remarks: _____

The above is certified to be true at the time of testing.

Firm Name: NEW-TEX Fire Protection Sys LLC Certified Tester Name: Octavio Ramirez (Tavo)

Firm Address: 5696 Burning Tree Cert. Tester #: BP0001229 Lic. Exp. Date: 3-22-26

Firm Phone: 915-497-8527 EPWU Technician #: 834

- * TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS
 ** USE ONLY MANUFACTURER'S REPLACEMENT PARTS

El Paso Water - 210 N. Lee Street - El Paso, TX 79901 - Phone (915) 594-5440 - Fax (915) 594-5789

BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

NAME OF PWS: El Paso Water PWS I.D. #: 0710002

OWNER NAME: _____

BUSINESS NAME: El Paso Paper Box

MAILING ADDRESS: 24 Zane Grey St City: El Paso State: TX Zip: 79906

CUSTOMER REPRESENTATIVE: _____ Phone: _____ E-mail: _____

PREMISE ADDRESS: 24 Zane Grey St City: El Paso State: TX Zip: 79906

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

TYPE OF ASSEMBLY

- ☐ Reduced Pressure Principle
☐ Double Check Valve
☐ Pressure Vacuum Breaker

Meter Serial Number: 20969790

- ☒ Reduced Pressure Principle-Detector
☐ Double Check-Detector
☐ Spill-Resistant Pressure Vacuum Breaker

Manufacturer: Wilkins Size: 3/4

Model Number: 975XL Located At: west side of Bldg

Serial Number: 4889523 ☐ Domestic ☒ Fire Protection ☐ Lawn Irrigation

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? yes

	Reduced pressure Principle Assembly			Pressure Vacuum Breaker	
	Double Check Valve Assembly		Relief Valve	Air Inlet	Check Valve
	1st Check	2nd Check			
Initial Test	Held at <u>8.0</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>1.9</u> psid Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Opened at <u>3.7</u> psid Did not open <input type="checkbox"/>	Opened at _____ psid Did not open <input type="checkbox"/>	Held at _____ psid Leaked <input type="checkbox"/>
Repairs and Materials Used					
Test After Repair	Held at _____ psid Closed Tight <input type="checkbox"/>	Held at _____ psid Closed Tight <input type="checkbox"/>	Opened at _____ psid	Opened at _____ psid	Held at _____ psid

Test Date: 4/11/24 Test Type: ☐ Initial ☒ Annual ☐ Repair ☐ Relocation

Test Gauge Used: Make/Model: Pro Master S/N: 0854 Calibration Date: 1-10-23

Removed Assembly: Manufacturer: _____ Model: _____ Size: _____ S/N: _____

Remarks: _____

The above is certified to be true at the time of testing.

Firm Name: NEW-TEX Fire Protection Sys LLC Certified Tester Name: Octavio Ramirez (Tavo)

Firm Address: 5696 Burning Tree Cert. Tester #: BP0001229 Lic. Exp. Date: 3-22-26

Firm Phone: 915-497-8527 EPWU Technician #: 834

- * TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS
 ** USE ONLY MANUFACTURER'S REPLACEMENT PARTS

El Paso Water - 210 N. Lee Street - El Paso, TX 79901 - Phone (915) 594-5440 - Fax (915) 594-5789

BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

NAME OF PWS: El Paso Water PWS I.D. #: 0710002

OWNER NAME: _____

BUSINESS NAME: El Paso Paper Box

MAILING ADDRESS: 24 Zane Grey City: El Paso State: Tx Zip: 79906

CUSTOMER REPRESENTATIVE: _____ Phone: _____ E-mail: _____

PREMISE ADDRESS: 24 Zane Grey City: El Paso State: Tx Zip: 79906

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

TYPE OF ASSEMBLY

- ☒ Reduced Pressure Principle
☐ Double Check Valve
☐ Pressure Vacuum Breaker

Meter Serial Number: 17147081

- ☐ Reduced Pressure Principle-Detector
☐ Double Check-Detector
☐ Spill-Resistant Pressure Vacuum Breaker

Manufacturer: Wilkins

Size: 3"

Model Number: 375

Located At: North Side of Bldg

Serial Number: 1A05 M0353

☐ Domestic ☐ Fire Protection ☐ Lawn Irrigation

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? YES

	Reduced pressure Principle Assembly			Pressure Vacuum Breaker	
	Double Check Valve Assembly		Relief Valve	Air Inlet	Check Valve
	1st Check	2nd Check			
Initial Test	Held at <u>7.8</u> psid Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>1.9</u> psid Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Opened at <u>3.6</u> psid Did not open <input type="checkbox"/>	Opened at _____ psid Did not open <input type="checkbox"/>	Held at _____ psid Leaked <input type="checkbox"/>
Repairs and Materials Used					
Test After Repair	Held at _____ psid Closed Tight <input type="checkbox"/>	Held at _____ psid Closed Tight <input type="checkbox"/>	Opened at _____ psid	Opened at _____ psid	Held at _____ psid

Test Date: 4/11/24 Test Type: ☐ Initial ☒ Annual ☐ Repair ☐ Relocation

Test Gauge Used: Make/Model: Pro Master S/N: 0854 Calibration Date: 1-2-24

Removed Assembly: Manufacturer: _____ Model: _____ Size: _____ S/N: _____

Remarks: _____

The above is certified to be true at the time of testing.

Firm Name: TDE Backflow Services Certified Tester Name: Octavio Ramirez (Tavo)

Firm Address: 10219 Conquistador Cert. Tester #: BP0001229 Lic. Exp. Date: 3-22-26

Firm Phone: 915-873-0873 EPWU Technician #: 539

- * TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS
 ** USE ONLY MANUFACTURER'S REPLACEMENT PARTS

El Paso Water - 210 N. Lee Street - El Paso, TX 79901 - Phone (915) 594-5440 - Fax (915) 594-5789

BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

NAME OF PWS: El Paso Water PWS I.D. #: 0710002

OWNER NAME: _____

BUSINESS NAME: El Paso Paper Box

MAILING ADDRESS: 24 Zane Grey St City: El Paso State: TX Zip: 79906

CUSTOMER REPRESENTATIVE: _____ Phone: _____ E-mail: _____

PREMISE ADDRESS: 24 Zane Grey St City: El Paso State: TX Zip: 79906

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

TYPE OF ASSEMBLY

- ☒ Reduced Pressure Principle
☐ Double Check Valve
☐ Pressure Vacuum Breaker

Meter Serial Number: 17147081

- ☐ Reduced Pressure Principle-Detector
☐ Double Check-Detector
☐ Spill-Resistant Pressure Vacuum Breaker

Manufacturer: Wilkins

Size: 1 1/2

Model Number: 975 XL

Located At: north side of Bldg

Serial Number: 3416782

☒ Domestic ☐ Fire Protection ☐ Lawn Irrigation

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? yes

	Reduced pressure Principle Assembly			Pressure Vacuum Breaker	
	Double Check Valve Assembly		Relief Valve	Air Inlet	Check Valve
	1st Check	2nd Check			
Initial Test	Held at _____ psid Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Held at _____ psid Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Opened at _____ psid Did not open <input type="checkbox"/>	Opened at _____ psid Did not open <input type="checkbox"/>	Held at _____ psid Leaked <input type="checkbox"/>
Repairs and Materials Used	<u>Complete Repair Kit</u>				
Test After Repair	Held at <u>8.2</u> psid Closed Tight <input type="checkbox"/>	Held at <u>2.0</u> psid Closed Tight <input type="checkbox"/>	Opened at <u>4.0</u> psid	Opened at _____ psid	Held at _____ psid

Test Date: 4/11/24 Test Type: ☐ Initial ☒ Annual ☐ Repair ☐ Relocation

Test Gauge Used: Make/Model: Pro Master S/N: 0854 Calibration Date: 1-10-2324

Removed Assembly: Manufacturer: _____ Model: _____ Size: _____ S/N: _____

Remarks: _____

The above is certified to be true at the time of testing.

Firm Name: TDE Backflow Services Certified Tester Name: Octavio Ramirez (Tavo)

Firm Address: 10219 Conquistador Cert. Tester #: BP0001229 Lic. Exp. Date: 3-22-26

Firm Phone: 915-873-0873 EPWU Technician #: 539

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS
 ** USE ONLY MANUFACTURER'S REPLACEMENT PARTS

El Paso Water - 210 N. Lee Street - El Paso, TX 79901 - Phone (915) 594-5440 - Fax (915) 594-5789

BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

NAME OF PWS: El Paso Water PWS I.D. #: 0710002

OWNER NAME: _____

BUSINESS NAME: El Paso Paper Box

MAILING ADDRESS: 24 Zane Grey St City: El Paso State: TX Zip: 79906

CUSTOMER REPRESENTATIVE: _____ Phone: _____ E-mail: _____

PREMISE ADDRESS: 24 Zane Grey St City: El Paso State: TX Zip: 79906

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

TYPE OF ASSEMBLY

- ☐ Reduced Pressure Principle
☐ Double Check Valve
☒ Pressure Vacuum Breaker

Meter Serial Number: 17147081

- ☐ Reduced Pressure Principle-Detector
☐ Double Check-Detector
☐ Spill-Resistant Pressure Vacuum Breaker

Manufacturer: Febco

Size: 1 1/2

Model Number: 765

Located At: north side of Bldg

Serial Number: H031239

☐ Domestic ☐ Fire Protection ☒ Lawn Irrigation

Is the assembly installed in accordance with manufacturer recommendations and/or local codes? yes

	Reduced pressure Principle Assembly			Pressure Vacuum Breaker	
	Double Check Valve Assembly		Relief Valve	Air Inlet	Check Valve
	1st Check	2nd Check			
Initial Test	Held at _____ psid Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Held at _____ psid Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Opened at _____ psid Did not open <input type="checkbox"/>	Opened at <u>1.8</u> psid Did not open <input type="checkbox"/>	Held at <u>2.0</u> psid Leaked <input type="checkbox"/>
Repairs and Materials Used					
Test After Repair	Held at _____ psid Closed Tight <input type="checkbox"/>	Held at _____ psid Closed Tight <input type="checkbox"/>	Opened at _____ psid	Opened at _____ psid	Held at _____ psid

Test Date: 4/11/24 Test Type: ☐ Initial ☒ Annual ☐ Repair ☐ Relocation

Test Gauge Used: Make/Model: Pro Master S/N: 0854 Calibration Date: 1-2-24

Removed Assembly: Manufacturer: _____ Model: _____ Size: _____ S/N: _____

Remarks: _____

The above is certified to be true at the time of testing.

Firm Name: TDE Backflow Services Certified Tester Name: Octavio Ramirez (Tavo)

Firm Address: 10219 Conquistador Cert. Tester #: BP0001229 Lic. Exp. Date: 3-22-26

Firm Phone: 915-873-0873 EPWU Technician #: 539

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS

** USE ONLY MANUFACTURER'S REPLACEMENT PARTS

El Paso Water - 210 N. Lee Street - El Paso, TX 79901 - Phone (915) 594-5440 - Fax (915) 594-5789